



Institut Pasteur de Lille
Unité de Sécurité Microbiologique – Microbiological Safety Unit
1 rue du Professeur Calmette – BP 245 – 59019 Lille Cedex – France

REMOVAL OF MICROORGANISMS FROM WATER BY GEYSER FILTERS

According to a test protocol based on filtration of artificially contaminated ultrapure water, GEYSER filters ARAGON BIO were able to remove bacterial and viral contamination with the following values (obtained in separate experiments):

- *Legionella pneumophila* serogroup 1 (CIP 103854), mean removal 99.99987% (5.9 log)
- *Salmonella* Typhimurium (ATCC 14028), mean removal 99.998% (4.8 log)
- Poliovirus strain Sabin type 1, mean removal 99.84% (2.8 log)
- Rotavirus strain simiens SA114F1, mean removal 99.99% (4.0 log)
- Hepatitis A virus strain HM175/18f (ATCC VR-1402), mean removal 96% (1.4 log)

Lille, September 3rd, 2014



**Unité de Sécurité
Microbiologique**

1, rue du professeur Calmette
BP 245 - 59019 Lille cedex
TÉL. 03 20 87 78 53 - Fax : 03 20 87 77 74

Dr. Michèle Vialette
Head of the Microbiological Safety Unit
Institut Pasteur de Lille